

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Friday, July 24, 2015
Partial Correction 1 Misc 1		TWO TEMPORARY CONDUITS BORED FROM XFMR LOCATION TO NEW BUILDING.	
Partial Correction 2 Misc 1		FOUR 4" + TWO 3" PERMANENT PVC CONDUITS OK TO COVER FROM XFMR LOCATION TO 30' SOUTH TOWARD NEW BUILDING;	

Comments: