

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143056, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, Unit:310, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Friday, July 24, 2015
Partial Correction 1      Misc 1		OK TO COVER WHEN READY WALL CAVITY OPENED FOR INSTALLATION OF ELECTRICAL AND PLUMBING MODIFICATIONS AT LOCATIONS: 3D119; <b>AFTER MC ELECT CABLE IS SECURED WITHIN 12" OF ENTRY TO BOXES -- 3D127; 128; 129;</b>	
<b>Above Ceiling Inspection</b>	John Borns	Partial	Friday, July 24, 2015
Partial Correction 1      Misc 1		NO ISSUES FOUND ON RELATED <b>ABOVE-CEILING DRAIN AND VENT PLUMBING WORK ABOVE AND BELOW 3D119;</b>	

**Comments:**