

CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

ADDRESS: 1170 NE Douglas St. PERMIT NUMBER: NA
LOT NUMBER: SUBDIVISION: Platt's Closet INSPECTION: Re-Occupancy
CONTRACTOR: Design/Build, Portland Blvd. PHONE NUMBER:
PROJECT: Storm Damage

1. FOOTING	S <u> </u> U <u> </u>	7. GAS PIPING	S <u> </u> U <u> </u>	12. POOL BONDING	S <u> </u> U <u> </u>
2. SEWER/WATER	S <u> </u> U <u> </u>	8. GAS SERVICE	S <u> </u> U <u> </u>	13. SPRINKLER SYSTEM	S <u> </u> U <u> </u>
3. FRAMING	S <u> </u> U <u> </u>	9. GROUND PLUMBING	S <u> </u> U <u> </u>	14. OCCUPANCY	S <u> </u> U <u> </u>
4. MECHANICAL	S <u> </u> U <u> </u>	10. TOP ROUGH PLUMBING	S <u> </u> U <u> </u>	15. FINAL APPROVAL	S <u> </u> U <u> </u>
5. ELECTRICAL	S <u> </u> U <u> </u>	11. DECK PIERS	S <u> </u> U <u> </u>	16. EROSION CONTROL	S <u> </u> U <u> </u>
6. ELECTRIC SERVICE	S <u> </u> U <u> </u>				

storm damage affecting this space has been repaired except

- 1) Permanent roof repairs are pending
- 2) Gas piping at rooftop is to be replaced/ repaired beginning presently.
- 3) Lighted sign at facade is to be replaced. Must be shop-labeled per NBC.

Concurrent with above, ok to resume business. Certificate of occupancy issued 3/28/2011 is hereby re-activated.

INSPECTOR: John Burns DATE: 7/28/15 TIME: MILEAGE:

DO NOT COVER OVER WORK UNTIL APPROVED - CALL FOR REINSPECTION OF UNSATISFACTORY WORK

LEGEND:

*S = SATISFACTORY

*U = UNSATISFACTORY (reinspection required)

3/28/11