

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

July 28, 2015

RIVER OAK CONSTRUCTION
621 NE WOODS CHAPEL RD
LEES SUMMIT, MO 64064

Permit No: PRCOM20151616
Project Title: NATIONAL EXCELSIOR
Project Address: 2600 NE INDEPENDENCE AVE, Unit:A, LEES SUMMIT, MO 64064
Parcel Number: 52240030800000000
Location: LAKEWOOD BUSINESS CENTER ON I-470 PLAT N LOT 11
Type of Work: CHANGE OF TENANT
Occupancy Group: MERCANTILE
Description: INTERIOR ALTERATIONS FOR CHANGE OF TENANT FOR WHOLESALE HVAC PARTS - SERVED BY EXISTING WAREHOUSE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Licensed Contractors **Reviewed By: Tara Mitchell** **Approved**

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the name of the licensed general contractor.

Building Plan Review **Reviewed By: Joe Frogge** **Approved**

Fire Plan Review **Reviewed By: Jim Eden** **Approved with Conditions**

1. Provide an exit light over the front door unless already existing.
2. IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Submit plans for relocated alarm notification appliances.

3. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or

modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for modification of fire sprinkler coverage.

4. IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

One fire extinguisher in the front office will be fine.

5. IFC 901.6 Inspection, testing and maintenance.

Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.

Existing systems shall have documentation of a current annual inspection. Verified at inspection.

6. What type of product does the company sell, and how will it be stored in the warehouse? Submit a rack storage plan if that is how product will be stored.

Fire Plan Review

Reviewed By: Jim Eden

Pending

1. What type of product does the company sell, and how will it be stored in the warehouse? Submit a rack storage plan if that is how product will be stored.

2. IFC 901.6 Inspection, testing and maintenance.

Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.

Existing systems shall have documentation of a current annual inspection. Verified at inspection.

3. IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

One fire extinguisher in the front office will be fine.

4. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for modification of fire sprinkler coverage.

5. IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

