

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151648, Building Permit - Commercial
Address: 1190 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Wednesday, July 29, 2015

Corrective Action Required

1	Misc 1	METTALIC ELECTRICAL BOXES NOT FOUND TO BE GROUNDED
---	--------	--

Corrective Action Required

2	Misc 1	NEC 300-11, 330.30 & 334-10 INSTALLATION OF MC ELECTRICAL CABLE: NOT SECURELY FASTENED WITHIN 12" OF ENTRY TO BOXES.
---	--------	--

Corrective Action Required

3	Misc 1	BULKHEAD AT REAR NOT EXPOSED FOR INSPECTION
---	--------	---

Comments: