

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20151707, Building Permit - Commercial  
Address: 1160 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	John Borns	Partial	Thursday, July 30, 2015

Partial Correction

1	Misc 1	GAS PIPING PRESSURE TEST HELD STEADY AT $\geq 10$ PSI FOR $\geq 10$ MIN ON PIPING FOR UNITS: 1194 (UNIT VACANT) 1192 (THAI SPICE) 1190 (SPRING NAILS) 1188 (UNIT VACANT) 1186 (NATURAL WAY CHIROPRACTIC)
2	Misc 1	ADDRESS LABELING OF GAS SERVICE ENTRY PIPE: HANG PERMANENT TAG FROM LOAD SIDE ENTRY PIPE.

<b>Gas Piping Inspection - Commercial</b>	John Borns	Failed	Thursday, July 30, 2015
---	------------	--------	-------------------------

Corrective Action Required

1	Misc 1	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. SEE GAS PIPING AT METER AND ROOFTOP.
---	--------	--

Comments: