

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151648, Building Permit - Commercial
Address: 1190 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Friday, July 31, 2015

Comments: FIRE DEPARTMENT INSPECTOR TO VISIT PRESENTLY. IF NO ADDITIONAL EXIT SIGNS, EMERGENCY LIGHTS AND ASSOCIATED WIRING ARE REQUIRED THEN OK TO COVER NEW & MODIFIED WALLS. CALL FOR INSPECTION WHEN CEILING GRID IS IN PLACE AND ABOVE-CEILING SYSTEMS ARE READY FOR INSPECTION.