

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Not Ready	Friday, July 31, 2015

Partial Correction

1 Misc 1

1ST FLOOR: NO CHANGE FROM 7/30. PLUMBING CONTRACTOR NOT READY AT EXTERIOR WALLS (BOCA PLATES, ETC). ELECTRICAL CONTRACTOR SAYS SHIELD PLATES ON ORDER.

Corrective Action Required

2 Misc 1

2ND FLOOR:
CORRIDOR ABOVE-CEILING: FIRE-CAULKING OF WALL PENETRATIONS IN JOIST BAYS NOT COMPLETED

Comments: