

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150311, Building Permit - Commercial  
Address: 2821 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, July 31, 2015

Partial Correction  
1 Misc 1

TEMPORARY SERVICE ONLY-OK FOR METER RELEASE

<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, July 31, 2015
---------------------------------------------------------------	--------------	---------	-----------------------

Partial Correction  
1 Misc 1

UE OK BELOW:  
-SERVICE SECONDARY RACEWAYS FROM TRANSFORMER MIDWAY TO  
BUILDING  
-LIGHT POLE CIRCUIT AT MIDDLE OF PARKING LOT

**Comments:**