

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151452, Building Permit - Commercial
Address: 516 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Lawn Sprinkler Final	John Borns	Passed	Monday, August 03, 2015

**Comments: REPORT OF TEST OF BACKFLOW PREVENTION DEVICE RECEIVED PER BEN HASKAMP
8/3/15. CLOSE PERMIT.**