

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141079, Building Permit - Commercial
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mike Copeland Codes Commercial		Failed	Monday, August 03, 2015

Corrective Action Required

1	Misc 1	-OBTAIN FINAL APPROVAL FROM THE FOLLOWING DEPARTMENTS: PUBLIC WORKS, PLANNING AND DEVELOPMENT, FIRE. -INSTALL 4 3" SCREWS IN THE STRIKE SIDE OF THE ENTRY DOORS AND DOORS WITH GRADE ACCESS -INSTALL WATER HAMMER ARRESTORS ON ALL LAUDRY VALVES
---	--------	--

Alarm Test	Michael Weissenbach	Passed	Monday, August 03, 2015
-------------------	---------------------	--------	-------------------------

Sprinkler - Flow Test	Joe Dir	Passed	Monday, August 03, 2015
------------------------------	---------	--------	-------------------------

Comments: