

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mike Copeland	Failed	Monday, August 03, 2015

Corrective Action Required

1	Misc 1	FRAMING OF CEILING IN CORRIDORS TO HANG ROCK NO TRADES IN CEILING- B,1,2-
Partial Correction		
2	SECOND FLOOR	BEHIND TUBS ONLY INSPECTION: SEAL SPRINKLER PENETRATIONS
Partial Correction		
3	THIRD FLOOR	

Comments: