

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151270, Building Permit - Residential
Address: 3102 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Mike Copeland	Passed	Monday, August 03, 2015

Water Service Inspection - Residential	Mike Copeland	Failed	Monday, August 03, 2015
---	---------------	--------	-------------------------

Corrective Action Required
1 Misc 1

METER IS SET 9" FROM THE LID.

14"-18" ALLOWED

Comments: