

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151520, Building Permit - Commercial
Address: 226 SE DOUGLAS ST, Unit:205, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	John Borns	Passed	Wednesday, August 05, 2015
Final Plumbing Inspection - Commercial	John Borns	Passed	Wednesday, August 05, 2015

Comments: AIR ADMITTANCE VALVE IS ALLOWED AS EXCEPTION DUE TO OBSTRUCTIONS IN WALL CAVITY ABOVE SINK. ACCESS TO DRAIN LINE OFFSET ABOVE FIRST FLOOR CEILING WAS PREVENTED DUE TO CEILING ACCESS PANEL BEING FASTENED AND UNOPENABLE. CLOSE PERMIT.