

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143056, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:310, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, August 05, 2015
Partial Correction 1 Misc 1		NO ISSUES FOUND ON RELATED ABOVE-CEILING DRAIN AND VENT PLUMBING WORK ABOVE AND BELOW 3D119;	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 3D127; 128; 129;	

Comments: NON-COMPLIANT OLD WORK TO BE CORRECTED:

- 1) FIRE-CAULK SPRINKLER PIPE PENETRATION OF CMU STAIR SHAFT WALL**
- 2) STRAP MC CABLE TO WALL WITHIN 12" OF ENTRY TO BOXES**