

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151156, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, August 05, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY COMPONENTS OF FIRE-RATED WALLS AT LOCATIONS: FRAMING AND SHAFT LINER BOARD ON (6.1) FROM (B) TO (C); SHAFT WALLS @ 5A095 N & 097 N;	
Partial Correction 2 Misc 1		SMOKE WALL GWB ON (3.5) FROM (A) TO (B) & FROM (C) TO (D);	
In-wall Inspection	John Borns	Partial	Wednesday, August 05, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 5A015A; 5A007 THRU 5A021; CORR 081 (1) THRU (5) EAST WALL; CORR 102 (1) THRU (5) WEST WALL; SPACE 070A; 087; CORRIDORS 5A081A & 5A102 FROM (1) TO (7.5); PATIENT ROOMS 5A002 - 006 & 023 - 027; 5A068; 069; 081 S; 082; 083; 084; 085; 086; 087; 089; 093; 095; 097; [072 - 078; OK TO COVER SHOWERS AT PATIENT ROOMS: 5A010A - 5A020A; 001-009; 021-030; PROVIDE CERTIFICATION THAT ALL FLOOR PENETRATIONS ARE FIRE-STOPPED;	
Above Ceiling Inspection	John Borns	Partial	Wednesday, August 05, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING	

SYSTEMS @ FOLLOWING SPACES: **SHOWERS AT 015-017;**

Comments: