

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, August 06, 2015

Corrective Action Required

1 Misc 1  
Partial Correction

1ST FLOOR:

2 Misc 1

**2ND FLOOR:**  
**CORRIDOR CEILING SINGLE LAYER 5/8" TYPE X GWB OK TAPE, MUD, & FIRE-SEAL.**

Corrective Action Required

3 Misc 1

3RD FLOOR:

**Comments:**