

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141079, Building Permit - Commercial
Address: 3361 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mike Copeland Codes Commercial		Failed	Thursday, August 06, 2015

Corrective Action Required

1	Misc 1	-OBTAIN FINAL APPROVAL FROM THE FOLLOWING DEPARTMENTS: PUBLIC WORKS, PLANNING AND DEVELOPMENT, FIRE.
---	--------	--

Partial Correction

2	Misc 1	FIRST AND SECOND FLOORS APPROVED FOR TEMPORARY OCCUPANCY ONLY. THIRD FLOOR ALL EAST UNITS ARE MISSING LINE SET INSULATION . FOURTH FLOORS NEED TO BE INSPECTED.
---	--------	---

Comments: