PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151156, Building Permit - Commercial Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Passed	Saturday, August 08, 2015
Partial Correction 1 Misc 1	l		MPONENTS OF FIRE-RATED WALLS AT FT LINER BOARD ON (6.1) FROM (B) TO (C); N;
Rated Assembly Inspection	John Borns	Partial	Saturday, August 08, 2015
Partial Correction 1 Misc 1	l	OK TO COVER WHEN READY COMPONENTS OF FIRE-RATED WALLS AT LOCATIONS: FRAMING AND SHAFT LINER BOARD ON (6.1) FROM (B) TO (C); SHAFT WALLS @ 5A095 N & 097 N;	
Partial Correction 2 Misc 1			ALL; 5A096 E,N,W BOTH FACES + S WALL; ALL + FIRE CAULK @ SW CORNER;
	S	SMOKE WALL GWB ON (3.5) FROM (A) TO (B) TO (C) TO (D);	
Above Ceiling Inspection	John Borns	Partial	Saturday, August 08, 2015
Partial Correction 1 Misc 1			B CEILING FRAMING + ABOVE-CEILING 5: SHOWERS AT 015-017; [008-014; 018; 019;
In-wall Inspection	John Borns	Partial	Saturday, August 08, 2015

Partial Correction	
1 Misc 1	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: 5A015A; 5A007 THRU 5A021; CORR 081 (1) THRU (5) EAST WALL; CORR 102 (1) THRU (5) WEST WALL; SPACE 070A; 087; CORRIDORS 5A081A & 5A102 FROM (1) TO (7.5); PATIENT ROOMS 5A002 - 006 & 023 - 027; 5A068; 069; 072; 078; 081 S; 082; 083; 084; 085; 086; 087; 089; 093; 095; 097; [
	OK TO COVER SHOWERS AT PATIENT ROOMS: 5A010A - 5A020A; 001-009; 021-030;
	PROVIDE CERTIFICATION THAT ALL FLOOR PENETRATIONS ARE FIRE-STOPPED;
Partial Correction 2 Misc 1	OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: BATHROOMS @ 028-030;

Comments: