

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, August 10, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY COMPONENTS OF 2-HR FIRE-RATED WALLS AT LOCATIONS: TWO LAYERS 5/8" TYPE X GWB TOP-OUT AT CORR A112 OUTSIDE A114 SOUTH;	
Partial Correction 2 Misc 1		GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: A111 E & S; EXISTING LOBBY EAST WALL OPPOSITE A143; ELECT A117 W, S, E WALLS; WALL SEPARATING A139 & A140; RECESSES/INFILLS AT EX CORR 11 @ NEW D.F. & THREE LOCATIONS @ EX CORR 7 N END; A148 OPPOSITE D.F. @ CORRIDOR; A108 N WALL; A135 S, E, N(EXCEPT WF STEEL BEAM @ TOP); A124 N WALL; S WALL OF SPACES 120 BAYS 5 & 6, 123, 122; BEAM WRAP @ 108 N; 113 E & W; 116; 120 N WALL @ BAYS 1-4; 136; 143; 155; FIRE WALLS W/ STAFF LOUNGE A143 @ N & W; HALLWAY SIDE OF SOILED UTILITY A135; A130 & A124 TO 9' AFF; A154 N & W; A116 W, N, E WALLS CORR FACE; 129 N; 130 N; A117 N WALL; A126 NW TO 10' AFF; A118 S; A150 N, W TO 10' AFF; A152 W, S;	
Underground Electrical Inspection - Commercial	John Borns	Passed	Monday, August 10, 2015

Comments: OK TO ENCASE AND COVER WHEN READY THREE 3/4" STEEL/PVC CONDUITS THROUGH WEST WALL AND 12' NW FOR LIGHTING AND DATA/COMM AT ENTRANCE CANOPY.