

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141139, Building Permit - Commercial
Address: 3371 SW KESSLER DR, Unit:G1, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|---------------|----------|-------------------------|
| All Rough Inspection - Commercial | Mike Copeland | Failed | Monday, August 10, 2015 |

Corrective Action Required

| | | |
|---|-------------------|---|
| 1 | FRAMING/STRUCTURE | -NAIL ROOF TRUSSES -INSTALL ANCHOR BOLTS AS REQUIRED |
|---|-------------------|---|

Comments: