

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150657, Building Permit - Commercial  
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Failed	Tuesday, August 11, 2015
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Passed	Tuesday, August 11, 2015
<b>Footing Inspection - Commercial</b>	John Borns	Passed	Tuesday, August 11, 2015

**Comments: NO ISSUES FOUND ON INSTALLATION OF GROUND RODS, GROUND RING, AND UFER GROUND TERMINATIONS AND LEADS. OK TO POUR WHEN READY PERIMETER TRENCH FOOTING PREPARED PER DRAWING.**