

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141074, Building Permit - Commercial
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Tuesday, August 11, 2015

Partial Correction

1	FIRST FLOOR	2ND LAYER CORRIDOR LID APPROVED UNITS 1ST LAYER APPROVED
---	-------------	---

Partial Correction

2	SECOND FLOOR	2ND LAYER CORRIDOR LID APPROVED 2 HOUR CONDITIONS APPROVED
---	--------------	---

Partial Correction

3	THIRD FLOOR	2ND LAYER CORRIDOR LID APPROVED
---	-------------	---------------------------------

Partial Correction

4	LOWER LEVEL	UNITS FIRST LAYER APPROVED 2 HOUR CONDITIONS APPROVED
---	-------------	--

Partial Correction

5	FOURTH FLOOR	CORRIDOR LID APPROVED
---	--------------	-----------------------

Above Ceiling Inspection	Mike Copeland	Failed	Tuesday, August 11, 2015
---------------------------------	---------------	--------	--------------------------

Corrective Action Required

1	Misc 1	LANDINGS FOR STAIRS, ADD JOIST HANGER AND TOE NAIL JOISTS
---	--------	---

Comments: