

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150869, Building Permit - Commercial
Address: 3680 NE AKIN DR, Unit:132, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Passed	Wednesday, August 12, 2015

Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Wednesday, August 12, 2015
--	--------------	--------	----------------------------

Corrective Action Required

1	Misc 1	-OBTAIN FIRE APPROVAL -INSTALL RESTROOM SIGNAGE -ADJUST RESTROOM DOORS
---	--------	--

Comments: