

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150657, Building Permit - Commercial
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Passed	Wednesday, August 12, 2015

Comments: OK TO COVER WHEN READY 2" SCH 40 PVC SECONDARY SERVICE CONDUIT FROM METER RACK TO BUILDING S WALL + 2 GROUND RODS & G.E.C.S FROM RODS AND FOOTING + RACK GROUNDING.