

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141080, Building Permit - Commercial  
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mike Copeland	Not Ready	Wednesday, August 12, 2015

Corrective Action Required

1	Misc 1	rated ceiling corridors-
---	--------	--------------------------

remove sheetrock from walls in corridors no inspection was performed.  
only ceilings were approved to rock

<b>All Rough Inspection - Commercial</b>	Mike Copeland	Failed	Wednesday, August 12, 2015
--	---------------	--------	----------------------------

Partial Correction

1	LOWER LEVEL	-PROVIDE ENGINEER FIX FOR LVL OVERDRILL -SEAL BETWEEN FLOORS -SEAL ALL DRAFTSTOPS
---	-------------	---

Comments: