

## Inspection Summary

---

Permit #: PRCOM20143335, Building Permit - Commercial  
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Commercial</b>	John Borns	Passed	Wednesday, August 12, 2015

**Comments: OK TO COVER WHEN READY 6" SDR 26 SEWER SERVICE LINE PER DRAWING.**