

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151193, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-------------------------|
| Rough Mechanical Inspection - Commercial | John Borns | Passed | Monday, August 17, 2015 |
| Rough Electrical Inspection - Commercial | John Borns | Passed | Monday, August 17, 2015 |
| Final Building Inspection - Commercial | John Borns | Passed | Monday, August 17, 2015 |
| Rough Plumbing Inspection - Commercial | John Borns | Passed | Monday, August 17, 2015 |

**Comments: NO CODES ISSUES FOUND ON FINAL INSPECTION. CONTROL WIRING AND SYSTEMS
REMAIN TO BE COMPLETED. STATE BOILER INSPECTION MUST BE SCHEDULED BY CONTRACTOR AND
COMPLETED PER STATE PRESSURE VESSEL CODE. CLOSE PERMIT.**