

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Not Ready	Monday, August 17, 2015

Partial Correction

1	LOWER LEVEL	-PROVIDE ENGINEER FIX FOR LVL OVERDRILL -SEAL BETWEEN FLOORS -SEAL ALL DRAFTSTOPS
---	-------------	---

Rated Assembly Inspection	Mike Copeland	Partial	Monday, August 17, 2015
----------------------------------	---------------	---------	-------------------------

Partial Correction

1	FIRST FLOOR	BEHIND TUBS APPROVED
---	-------------	----------------------

Partial Correction

2	SECOND FLOOR	BEHIND TUBS APPROVED
---	--------------	----------------------

Partial Correction

3	THIRD FLOOR	BEHIND TUBS APPROVED
---	-------------	----------------------

Comments: