

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Tuesday, August 18, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS; CORRIDOR CEILING AND WALLS;	
Partial Correction 2 Misc 1		2ND FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; AFTER ALL HOLD-DOWNS ARE TORQUED AND ALL FIRE-BLOCKING IS FULLY SEALED, OK TO COVER WALLS INCLUDING AT ELECTRICAL PANELS;	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING;	

Comments: