

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Partial	Wednesday, August 19, 2015

Partial Correction

1 LOWER LEVEL -STRAP MID ROOM

Partial Correction

2 SECOND FLOOR
-COMPLETE BATH FANS NORTH UNITS AND SOUTH UNITS
-FIRESTOP GTHROUGHOUT
-INSTALL PUDDY PADS ON BOXES WHERE REQUIRED
-STRAP TOP PLATES AT ROOF VENT AND AT MID ROOM ON BEARING WALLS
FIRESTOP LINE SETS

Comments: