

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Thursday, August 20, 2015

Partial Correction
1 Misc 1

1ST FLOOR:
OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS; CORRIDOR
CEILING AND WALLS; **CEILING AT SPACE 111;**

Partial Correction
2 Misc 1

2ND FLOOR:
OK TO COVER WHEN READY: CORRIDOR CEILING; AFTER ALL HOLD-DOWNS
ARE TORQUED AND ALL FIRE-BLOCKING IS FULLY SEALED, OK TO COVER
WALLS INCLUDING AT ELECTRICAL PANELS;

Comments: