

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141080, Building Permit - Commercial  
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mike Copeland	Failed	Thursday, August 20, 2015

Partial Correction

1	LOWER LEVEL	-STRAP MID ROOM
---	-------------	-----------------

Corrective Action Required

2	SECOND FLOOR	-SEAL LINE SETS
---	--------------	-----------------

Corrective Action Required

3	THIRD FLOOR	-STRAP AND FIRECAULK ALL DRYER VENTS -NAIL ALL HOLES IN STRUCTURAL STRAPS -INSTALL PUDDY PADS WHERE REQUIRED -COMPLETE ALL HAVC -BOND ALL METAL BOXES COMPLETE TIE DOWNS AND HANGERS END UNITS
---	-------------	---

Comments: