

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143335, Building Permit - Commercial  
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Passed	Friday, August 21, 2015

<b>Gas Service Inspection - Commercial</b>	John Borns	Failed	Friday, August 21, 2015
--	------------	--------	-------------------------

Corrective Action Required

1 Misc 1

LSCO 7-608: GAS PIPING TEST PRESSURE DECREASED DURING MONITORING PERIOD. CORRECT AND PRESSURIZE PIPING SYSTEM TO HOLD STEADY AT MINIMUM 10 PSI

<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, August 21, 2015
----------------------------------	------------	---------	-------------------------

Partial Correction

1

**Comments: GAS PIPING VISUAL INSPECTION APPROVED. PRESSURE TEST NOT APPROVED. GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: 101 SOUTH WALL**