

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, August 21, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS; CORRIDOR CEILING AND WALLS; CEILING AT SPACE 111;	
Partial Correction 2 Misc 1		2ND FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT ELEVATOR LOBBY	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT ELEVATOR LOBBY	
Partial Correction 4 Misc 1		4TH FLOOR: OK TO PRE-ROCK FOR HVAC DUCT AT BALCONY DOOR RECESSES AT E-412; E-414; E-423; E-427	
Rated Assembly Inspection	John Borns	Partial	Friday, August 21, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO TAPE, MUD & FIRE-STOP: RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT STAIRWELL WALLS. NO COMMON OR UTILITY AREAS PRE-ROCK: UNIT 113: GWB WALL AT DEAD SPACE ADJACENT TO CORRIDOR; UNIT 112: LID OF CLOSET AT EXT WALL; UNIT 132: CEILING ABOVE HVAC DUCT AT BR;	

Partial Correction
2 Misc 1

UNITS 101 & 102: CORR WALL @ COAT CLO;

2ND FLOOR:
CORRIDOR CEILING SINGLE LAYER 5/8" TYPE X GWB OK TAPE, MUD, &
FIRE-SEAL.

Comments: