

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141074, Building Permit - Commercial
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mike Copeland	Failed	Friday, August 21, 2015

Corrective Action Required

1	Misc 1	PULL SECONDARY CONDUCTORS AND GROUNDED CONDUCTORS AND LAND THEM.
		GOUNDING APPROVED.

Comments: