

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150741, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Friday, August 21, 2015

Corrective Action Required

1 Misc 1

COMPLETE PAINTING OF ROOFTOP GAS PIPE.

Corrective Action Required

2 Misc 1

COMPLETE CLEARING/CLEANING OF ROOFTOP AT UNIT FOOTPRINT

Corrective Action Required

3 Misc 1

STOREFRONT AREA NOT READY FOR INSPECTION.

Corrective Action Required

4 Misc 1

ICC 117.1 INSTALL HANDICAPPED-ACCESSIBLE RESTROOM SIGNS.

Corrective Action Required

5 Misc 1

RESOLVE FIRE DEPARTMENT ISSUES

Corrective Action Required

6 Misc 1

EMERGENCY EGRESS LIGHTING REQUIRED AT FRONT ENTRANCE

Corrective Action Required

7 Misc 1

INSTALLATION OF LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED.  
PER NEC 600.3, IF INTERNALLY LIGHTED MUST BE SHOP-LABELED. INSTALL NO  
NON-LABELED SIGN.

Corrective Action Required

8 Misc 1

ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE  
SERVICES ARE GROUPED LOOSE-HANG ADDRESS-STAMPED MEDALLION ON  
LOAD SIDE PIPE.

Corrective Action Required

9 Misc 1

**OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO PUBLIC OR  
CUSTOMERS PRIOR TO APPROVAL.**

**Comments:**