

## Inspection Summary

Permit #: PRCOM20150741, Building Permit - Commercial  
Address: 860 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	John Borns	Passed	Wednesday, August 26, 2015

**Comments: OK TO COVER/CLOSE WHEN READY CEILING-MOUNTED AND WALL-MOUNTED ELECTRICAL BOXES AND DEVICES AT STOREFONT AREA; NO ISSUES FOUND ON WIRING AND TERMINATIONS AT ELECTRICAL GEAR. LIGHTED SIGNS INSTALLED AND BEING WIRED AT ENTRANCE CANOPIES ARE LABELED PER NEC.**