

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20151156, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, August 26, 2015

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY COMPONENTS OF FIRE-RATED WALLS AT LOCATIONS: FRAMING AND SHAFT LINER BOARD ON (6.1) FROM (B) TO (C); SHAFT WALLS @ 5A095 N & 097 N; 5A095 E,S,W BOTH FACES + N WALL; 5A096 E,N,W BOTH FACES + S WALL; 5A097 E,S,W BOTH FACES + N WALL + FIRE CAULK @ SW CORNER; 076, 077, 078 INTERIOR FACE ONLY; 074 & 075 S WALL; CORR FACE ON (B) & (C) FROM (6) TO (7); 5A001 VERTICAL SHAFT AT N WALL; **WALL @ 5A029 N & 030 S, BUT HARD CORNER REQUIRED AT INTERSECION W/ CORRIDOR WALL; AT CORR 5A102 BULKHEAD AT DOUBLE DOOR NOT READY FOR INSPECTION;**

Comments: