

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141080, Building Permit - Commercial  
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mark Harding	Partial	Wednesday, August 26, 2015

Corrective Action Required

1	LOWER LEVEL	GARAGE SIDE OK
---	-------------	----------------

Corrective Action Required

2	SECOND FLOOR	items complete
---	--------------	----------------

Corrective Action Required

3	THIRD FLOOR	bond all metal boxes
---	-------------	----------------------

Corrective Action Required

4	FOURTH FLOOR	WIRE BATH VENTS, PUDDY PADS, 4" ROOF DRAIN CAULK NAIL STRAPS, SUPPORT ROOF DRAINS, BOND ALL BOXES, NAIL PLATES FOR PLUMBING.
---	--------------	--

<b>Sewer Service Inspection - Commercial</b>	Mark Harding	Passed	Wednesday, August 26, 2015
--	--------------	--------	----------------------------

Comments: