

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|----------------------------------|------------|----------|---------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Rated Assembly Inspection | John Borns | Partial | Thursday, August 27, 2015 |

Partial Correction
1 Misc 1

1ST FLOOR:
OK TO TAPE, MUD & FIRE-STOP:
RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT STAIRWELL WALLS. NO
COMMON OR UTILITY AREAS

PRE-ROCK:
UNIT 113: GWB WALL AT DEAD SPACE ADJACENT TO CORRIDOR; UNIT 112:
LID OF CLOSET AT EXT WALL; UNIT 132: CEILING ABOVE HVAC DUCT AT BR;
UNITS 101 & 102: CORR WALL @ COAT CLO;

Partial Correction
2 Misc 1

2ND FLOOR: OK TO TAPE, MUD & FIRE-STOP:

- CORRIDOR CEILING ONE LAYER 5/8" TYPE X GWB
- **RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT WALLS AT STAIRWELLS**

Comments: