

Certificate of Occupancy

Permit #: PRCOM20151379
Address: 228 NW MCNARY CT, LEES SUMMIT, MO 64086
Inspected On: Thursday, August 27, 2015
Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - John Borns Codes Commercial	Full C of O		Thursday, August 27, 2015

Comments:

E.C. IS TO UPDATE AND RE-PRINT PANEL SCHEDULES FOR BOTH ELECTRICAL PANELS.

NOTED:

- EXISTING PVC PIPING IN ABOVE-CEILING PLENUM -- NON-CONFORMING.
- EXISTING FLOOR DRAINS IN RESTROOMS ARE DEPRESSED BELOW HARD TILE BEYOND 1/4" MAX ALLOWABLE FOR ACCESSIBLE LOCATIONS.