

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20150741  
**Address:** 860 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086  
**Inspected On:** Thursday, August 27, 2015  
**Inspected By:** John Borns  
**Expiration Date:** 9/3/2015 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Thursday, August 27, 2015

Corrective Action Required:

1 Misc 1 COMPLETE PAINTING OF ROOFTOP GAS PIPE.

Corrective Action Required:

2 Misc 1 COMPLETE CLEARING/CLEANING OF ROOFTOP AT UNIT FOOTPRINT

Corrective Action Required:

8 Misc 1 ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE SERVICES ARE GROUPED LOOSE-HANG ADDRESS-STAMPED MEDALLION ON LOAD SIDE PIPE.