

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143335, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	John Borns	Passed	Thursday, August 27, 2015

Comments: OK TO COVER WHEN READY 4" SDR STORM DRAIN PIPING FROM S CANOPY COLUMN SW TO STORM DRAIN STRUCTURE PER APPROVED DRAWING.