

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Thursday, August 27, 2015

Corrective Action Required

1	LOWER LEVEL	GARAGE SIDE OK
---	-------------	----------------

Corrective Action Required

2	SECOND FLOOR	items complete
---	--------------	----------------

Corrective Action Required

3	THIRD FLOOR	bond all metal boxes
---	-------------	----------------------

Corrective Action Required

4	FOURTH FLOOR	support roof drains 4th floor attic
---	--------------	-------------------------------------

Rated Assembly Inspection	Mark Harding	Partial	Thursday, August 27, 2015
----------------------------------	--------------	---------	---------------------------

Partial Correction

1	FIRST FLOOR	BEHIND TUBS APPROVED tub traps
---	-------------	-----------------------------------

Partial Correction

2	SECOND FLOOR	BEHIND TUBS APPROVED tub traps
---	--------------	-----------------------------------

Corrective Action Required

3	THIRD FLOOR	tub traps
---	-------------	-----------

Corrective Action Required

4	FOURTH FLOOR	tub traps
---	--------------	-----------

Comments: