

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151707, Building Permit - Commercial
Address: 1160 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Passed	Thursday, August 27, 2015
Final Plumbing Inspection - Commercial	John Borns	Passed	Thursday, August 27, 2015

Comments: ALL NEW PIPING FROM METER BANK TO ROOFTOP & RTU'S HAS BEEN SUCCESSFULLY PRESSURE TESTED. WEATHER-EXPOSED PIPING HAS BEEN PAINTED. UNIT ADDRESS TAGS HAVE BEEN ATTACHED TO LOAD-SIDE PIPE AT METER BANKS. CLOSE PERMIT.