

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20143056, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:310, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Friday, August 28, 2015

Partial Correction
1 Misc 1

FOLLOWING MODIFIED SPACE(S) OK FOR USE PER SCOPE OF PERMIT: 3D119;
127; 128; 129;

**BREAK RM 3D126 OK FOR USE AFTER TWO ELECT RECEPTS WITHIN 6' OF
EDGE OF SINK ARE GFCI-PROTECTED AND BOX AT MICROWAVE RECEPTACLE
BOX IS EXTENDED FLUSH WITH COMBUSTIBLE SURFACE; ALSO, WATER
SUPPLY TO SINK YET TO BE CONNECTED.**

SUBJECT TO FIRE DEPARTMENT APPROVAL AT FINAL PHASE INSPECTION

Comments: BREAK RM 3D126 IS SCHEDULED FOR RE-INSPECTION 8/31.