

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151156, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, August 28, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY COMPONENTS OF FIRE-RATED WALLS AT LOCATIONS: FRAMING AND SHAFT LINER BOARD ON (6.1) FROM (B) TO (C); SHAFT WALLS @ 5A095 N & 097 N; 5A095 E,S,W BOTH FACES + N WALL; 5A096 E,N,W BOTH FACES + S WALL; 5A097 E,S,W BOTH FACES + N WALL + FIRE CAULK @ SW CORNER; 076, 077, 078 INTERIOR FACE ONLY; 074 & 075 S WALL; CORR FACE ON (B) & (C) FROM (6) TO (7); 5A001 VERTICAL SHAFT AT N WALL; WALL @ 5A029 N & 030 S **INCLUDING HARD CORNER AT INTERSECIION W/ CORRIDOR WALL; CORR 5A102 NORTH BULKHEAD AT DOUBLE DOOR;**

5A086 NE AT VERTICAL MECHANICAL CHASE: FRAMING + SHAFT LINER OK TO COVER W/ 5/8" TYPE X GWB

Comments: