

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Friday, August 28, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO COVER WHEN READY: EXTERIOR WALLS; UNIT WALLS; CORRIDOR CEILING AND WALLS; CEILING AT SPACE 111;	
Partial Correction 2 Misc 1		2ND FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT ELEVATOR LOBBY	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO COVER WHEN READY: CORRIDOR CEILING; ALL CEILINGS & WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY	
Partial Correction 4 Misc 1		4TH FLOOR: COMPLETION OF WALL CAVITY FIRE-BLOCKING IN PROGRESS. SHIELD/BOCA PLATING OF PLUMBING LINES IN PROGRESS. OK TO COVER WHEN READY ALL CEILINGS & WALLS EXCEPT AT STAIRWELLS & ELEVATOR LOBBY	
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, August 28, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO TAPE, MUD & FIRE-STOP: RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT STAIRWELL WALLS. NO COMMON OR UTILITY AREAS  PRE-ROCK: UNIT 113: GWB WALL AT DEAD SPACE ADJACENT TO CORRIDOR; UNIT 112:	

Partial Correction

2            Misc 1

LID OF CLOSET AT EXT WALL; UNIT 132: CEILING ABOVE HVAC DUCT AT BR;  
UNITS 101 & 102: CORR WALL @ COAT CLO;

2ND FLOOR: OK TO TAPE, MUD & FIRE-STOP:

- CORRIDOR CEILING AND **WALLS** ONE LAYER 5/8" TYPE X GWB
- RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT WALLS AT STAIRWELLS

**Comments:**