

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, August 31, 2015
Partial Correction 1 Misc 1		1ST FLOOR: OK TO TAPE, MUD & FIRE-STOP: RATED CEILINGS AND WALLS AT ALL UNITS EXCEPT STAIRWELL WALLS. NO COMMON OR UTILITY AREAS  PRE-ROCK: UNIT 113: GWB WALL AT DEAD SPACE ADJACENT TO CORRIDOR; UNIT 112: LID OF CLOSET AT EXT WALL; UNIT 132: CEILING ABOVE HVAC DUCT AT BR; UNITS 101 & 102: CORR WALL @ COAT CLO;	
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, August 31, 2015
Partial Correction 1 Misc 1		2ND FLOOR: OK TO TAPE, MUD & FIRE-STOP PRE-ROCK: <b>WALLS AT ELECT &amp; DATA RMS AT CORRIDOR</b>	
Partial Correction 3 Misc 1		3RD FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: <b>UNITS 317; 318; 323;</b>  <b>WALLS AT ELECT &amp; DATA RMS AT CORRIDOR</b>	
Partial Correction 4 Misc 1		<b>4TH FLOOR: OK TO TAPE, MUD &amp; FIRE-STOP ONE LAYER 5/8" TYPE X GWB AT: ELECT &amp; DATA RMS WALLS</b>	

**Comments:**